

DO NOT tamper with or cover smoke alarms

Never try to change or remove battery
from Green Band smoke alarms.



Fire Risk Management Unit

This is the Department of Human Services approved smoke alarm.

In an Emergency telephone "000" For Police, Fire Brigade or Ambulance

240V Smoke Alarm with built in self-charging non-removable Battery

GREEN POWER LIGHT

Indicates power supply to unit.


This should be lit when **power** to your house is available.

HUSH BUTTON

In case of a false Alarm, press the **HUSH** Button.

The smoke alarm will be silenced for 10 Minutes.

The smoke alarm will then reset itself.



TEST BUTTON

Press and hold **TEST** Button to perform a self test. It will make a "beep, beep, beep" sound.

Monthly testing recommended

Please call **131172** to report any problems with your smoke alarm e.g. if it fails to operate when testing.

REMEMBER: IF YOUR SMOKE ALARM SOUNDS AND **YOU KNOW IT IS A FALSE ALARM**, OPEN THE DOORS AND WINDOWS OR **WAVE A TOWEL/CARDBOARD UNDER THE ALARM** TO MOVE SOME CLEAN AIR THROUGH THE ALARM.

IF THERE IS A FIRE IN YOUR HOME EVACUATE AND CALL TRIPLE '000'.